

AS2293.3 APPENDIX B

DECLARATION OF COMPLIANCE FOR EMERGENCY ESCAPE LUMINAIRES AND EXIT SIGNS

(INFORMATIVE)

Manufacturer: Evolt Pty Ltd
Address: U5/105a Vanessa Street,
 Kingsgrove, NSW 2208, Australia



Last updated: 9 November 2020_V1.0

EMERGENCY ESCAPE LUMINAIRE / EXIT SIGN			
ORDER CODE	PRODUCT NUMBER	SKU	QTY
EV-RAZOR-16M Slimblade Recessed Emergency Exit	9336462026847	02684	4
EV-RAZOR-16M-B Slimblade Recessed Emergency Exit, Black	933646026854	02685	4
EV-RAZOR-16M-PRO-LK Lynk Razor Professional Recessed Emergency Slimblade Exit, 16M - w/wireless	9336462180662	18066	4
EV-RAZOR-16M-PRO-B-LK Lynk Razor Professional Recessed Emergency Slimblade Exit, 16M, Black - w/wireless	9336462180679	18067	4

<input type="checkbox"/> Emergency escape luminaire	<input type="checkbox"/> Centrally supplied
<input checked="" type="checkbox"/> Exit sign	<input checked="" type="checkbox"/> Self-contained
<input checked="" type="checkbox"/> Maintained	<input type="checkbox"/> Non-maintained
<input checked="" type="checkbox"/> Combined	

OPERATIONAL INFORMATION	
GENERAL	
Mains Voltage	240V~ 50Hz
Ambient temp.	0 to 40°C
Class	2
Diffuser type	Polycarbonate
BATTERY	
Number of cells	2
Type	LiFePO ₄
Nominal Voltage	6.4 V
Capacity	1500mAh
Part number	1302

TUV SUD (SHENZHEN)	
TEST	DESCRIPTION
Safety Standards	IEC 60598-2-2:2011 EN 60598-2-2:2012 IEC 60598-1:2014 / IEC 60598-2-22:2014 IEC 60598-2-1:1979/AMD1:1987 EN 60598-1:2015 / EN 60598-2-22:2014 EN 60598-2-1:1989 / EN 62493:2015 AS/NZS 60598.2.22:2005 AS/NZS 60598.2.1:2014+A1:2016 AS/NZS 60598.1:2017+Amdt AS/NZS 2293.3:2018
Safety Certification	SG PSB-LE-01423M1(CB) N8A 096151 0035(LVD)
Safety / Performance Test Report	211-1417675-100(CB) 681401767502(LVD) 6814019016301(SA)
EMC standards	EN 55015:2013/A1:2015 EN 6100-3-2:2014 EN 61000-3-3:2013 EN 61547:2009 AS/NZS CISPR 15: 2011
EMC Certification	E8A 096151 0038
EMC Test Report	687401729002
Thermal Report	SG PSB-LE-01423M1(CB)

DECLARATION OF COMPLIANCE

On the basis of the test reports specified, I declare that the emergency escape luminaire/ exit sign described in this document complies with the requirements of AS2293.3.

Title: Managing Director **Date:** 27/10/20

Signature:

ektor.com.au
E: sales@evolt.com.au
 P:1300 4EVOLT (438 658)

evolt
 the electrical evolution

NOTE: This declaration form should be completed in full. The completed form should be considered sufficient to verify compliance with AS 2293.3.

Ektor is dedicated to continuous product improvement. Datasheet is subject to change without notice, E&OE. Images are for illustrative purposes only.